

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

April 21, 2005

CLEARSTREAM WASTEWATER SYSTEMS, INC. JOHN BARNES / WAYNE PEYTON PO BOX 7568 BEAUMONT TX 77709

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED CLEARSTREAM WASTEWATER SYSTEMS, INC.

Product Name: CLEARSTREAM WASTEWATER TREATMENT SYSTEM

Model Number(s): 750NC (750 GPD)

Product File No: 20050176

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2010.

This approval is contingent upon compliance with the following stipulation(s):

- A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 750 gallons per day.
- This product may not be installed more than 18 inches below final grade.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less then or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- This product must be installed with a Spartan Chemical Co., Inc. model 9111 Vent T Connector fitting
  permanently connected to the inlet of the hose serving this product when the product is not served by a separate
  water supply connection.
- A septic tank (pretreatment tank/trash trap) with a volume of at least 50% of the gallon per day rating of this
  product must be installed upstream of this product.

This approval supercedes the approval issued on October 9, 2001, under product file number 20010475.

SBD-10564-E (N.10/97) File Ref: 05017601.DOC

CLEARSTREAM WASTEWATER SYSTEMS, INC.

Page 2

April 21, 2005

Product File No: 20050176

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010475.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mbeckwith@commerce.state.wi.us